Many country cottages are of small rateable value, and for the water consumed therein the price per 1,000 gallons will work out at ninepence at the most, whereas the farmer may willingly pay two shillings. It is not too much to say, therefore, that agricultural supplies, in themselves so important to national health, may make rural water-supplies practicable in a sense that has never before been contemplated.

Discussion.

The Author, in introducing the Paper, apologized for the fact that the Paper contained so little that was really engineering, but essentially engineering in rural water-supplies did not differ materially from engineering in any other branch of water-supply, and he had therefore referred only to those few points in which there were differences in degree. No reference had been made to sources of water-supply, because exactly the same kind of source was used in rural supplies as in any others. He had assumed that what was in the minds of the Council when asking him to write the Paper was piped supplies to rural areas, that being of great public interest at the present time.

Many hard words had been uttered about the disgraceful sanitary conditions that existed in some rural districts, and unfortunately they were largely true ; but it seemed to him to be only right that there should be some examination of the reason for the continual existence of those conditions, and he had therefore dealt with that subject.

As stated in the Paper, the farmer now required large quantities of pure water as a business asset, owing to different methods of agriculture being adopted and in particular owing to the Accredited Milk scheme, and he was prepared to pay what the urban dweller might consider a high price for water. That would make an enormous difference to the finance of rural water-supplies, and it would give the engineer a chance. Hitherto he had had to make do with very little, and, even so, he had often been ordered to cut his scheme down still further, with the result that the final result could not be regarded as entirely satisfactory ; but now, within limits, the engineer had an opportunity to lay out a rural scheme on really good engineering lines.

He had emphasized the influence of women upon rural water-supplies, and he thought that was very largely due to the lectures and demonstrations which had been given during the war by the Women's Institutes and the Women's Voluntary Services. The women in the villages had grasped very quickly the fact that many of the unsatisfactory conditions which they had hitherto accepted were not necessary, but could be done away with, and they were determined to do away with them. He would

recommend anyone who had any doubt on that subject to read a report of the National Federation of Women's Institutes which had just been published in the last circular of the British Waterworks Association. It was extremely interesting and stated definitely that women in rural areas wanted such things as piped water-supplies and were prepared to pay for them. Incidentally, he thought that engineers might look upon women in future as their allies in other matters than the question of water-supplies. When they knew what engineers could do, they would probably say that engineers should be given an opportunity to do it.

The Rural Water Supplies and Sewerage Act, 1944, imposed a definite obligation on local authorities to see that water was taken to houses and schools, unless the cost was entirely unreasonable, and the Minister of Health was the arbiter as to whether the cost was reasonable or not.

It often happened that the urban dweller, who had provided his water-supply and paid for it, did not see why he should contribute towards the cost of a water-supply for the rural dweller, whom he regarded as having been behindhand on the subject. That was very natural, but town and country could not be divorced. If epidemics occurred in the country they would reach the towns, and, moreover, the towns' milk was produced in the country. Therefore the extra contribution was a form of insurance on the part of the urban dweller, and he should regard it in the same way as he regarded any other insurance premium.

The figures given for agricultural demands by different people appeared to vary considerably, and he did not think they were known exactly at the present time. Probably cows were like human beings, in that some drank more than others. But, even when agreement was reached on what a normal cow required, there would still be the particular characteristics of the place to be considered, because in some places, for instance, a cow might drink half its water in the farmyard and the other half from a stream. All such matters should be taken into account by the engineer, who would have to use common sense in preparing a scheme.

The neglect to utilize rain water in Great Britain had been brought home to him very forcibly about 20 years ago, when visiting Palestine in connexion with the water-supply of Jerusalem. He had arrived there in a period of almost unprecedented drought—only 11 inches of rain having fallen in the preceding 12 months; but in the hotel at which he stayed, in the old city, he could still get a bath, because of the rain water that had been collected.

Sir Jonathan Davidson observed that the Paper was of great topical interest and the Author had clearly defined the problems connected with rural water-supplies.

He believed that it was an American who defined an engineer as a man who could do for half-a-crown what any fool could do for a sovereign, and that definition was particularly true of an engineer who was expected to carry out a scheme for a rural water-supply. The Author had shown

clearly that the chief problem was that of finance. When it was remembered that in many rural parishes a penny rate produced only a few shillings, it was obvious that the cost of any worth-while scheme would in many cases have to be spread over a wider area than that of the parish council. The provision in the Rural Water Supplies and Sewerage Act of 1944 making it compulsory for the rural district council to distribute the cost over the whole of its area and, if a Government grant in aid of the scheme was to be obtained, for the county council to contribute, led to the apparent injustice that a parish which had provided itself with a supply of water had to contribute to the cost of providing its less provident or less fortunately circumstanced neighbour with a water-supply, but, after all, the governing principle was the greatest good for the greatest number.

For the reasons which the Author had explained, not much had been stated in the Paper about the extent of the problem, and Sir Jonathan found it very difficult to ascertain that. At the end of 1939 the Minister of Health, or his representative in the House of Commons, said that there were in England and Wales 3,432 parishes without a piped water-supply and that they comprised about one-eighth of the rural population. A little more than a year later—in January 1941—in answer to another question in Parliament, it was stated that the number of parishes in England and Wales with piped supplies was more than 7,800. If those figures were put together—the number of parishes that were not served with a piped supply and the number that were so served—a total of 11,232 was obtained, of which 30 per cent. were without a piped supply; and that figure of 30 per cent. agreed with the figure given in the Government White Paper on “A National Water Policy” issued in 1944, provided that the average number of persons in the parishes not supplied was the same as that in the parishes supplied. He found it impossible, however, to reconcile with that the statement made at the end of 1939, that only one-eighth of the rural population was without a piped water-supply, as that would be only 12 per cent., instead of the figure of 30 per cent. given in the White Paper. He thought it should be assumed that the latest figures, which were those given in the White Paper, were the more nearly correct, and that 30 per cent. of the rural population, or about 2 million people, had yet to be supplied.

Again, there appeared to be some doubt as to the effect of the Government grant. The Rural Water Supplies Act of 1934 allocated £1,000,000 to be used to assist the promotion of rural water-supplies, and the Author had stated that works to the value of more than £6,000,000 had been constructed in consequence of that grant. The same figure of £6,000,000 was given in the Government White Paper, but the Minister who in 1939 gave the figure of the number of parishes without a piped water-supply then stated that the grant of £1,000,000 had produced schemes costing approximately £7,500,000, towards which contributions had been made by the county councils. It was not necessary to inquire too closely into the

difference between the £7,500,000 and the £6,000,000, but it was obvious that valuable work had been done by the grant already made, and under the Rural Water Supplies and Sewerage Act of 1944 a sum of £15,000,000 was made available for England and Wales. But it was necessary to scale that sum down considerably, for three reasons:—Firstly, it had to cover the installation of sewerage schemes; secondly, it would have to meet the increased costs, at any rate in the earlier years after the war; and, thirdly, it was not unreasonable to assume that the easier and cheaper schemes had already been carried out and that many of those which had not yet been touched had been left because they were more expensive. For those three reasons, the £15,000,000 would certainly not go nearly so far in proportion as the £1,000,000. Obviously it was very difficult to say whether the amount authorized would be sufficient to make up the deficiencies, but it provided valuable evidence that the Government had made up their minds to grapple properly with the problem, and it was not unreasonable to assume that if more money were found to be required it would be forthcoming.

With regard to the methods of supply, the Author had put forward very strong reasons in support of his plea for regional schemes, and Sir Jonathan agreed that where water was drawn mainly from surface sources and required treatment, such as filtration or treatment with chemical reagents, or possibly both, and it was necessary to have a skilled technical staff to supervise and control the supply, the scheme should be of sufficient size to justify paying the salaries or wages of such a staff. But where safe and ample supplies could be obtained from underground sources, as they could in certain parts of the country, it might be more feasible, at any rate at the beginning, to carry out more local schemes.

A very interesting scheme was in existence at Princes Risborough, which he believed was started about 16 or 17 years ago. There were ample safe underground supplies, and a considerable number of small pumping installations were put down, which were eventually coupled up and worked into a ring system of mains. With the introduction of electricity throughout great parts of the country, it was possible by the use of automatic controls to work a scheme of that kind with very little skilled attention. The pumps came into operation and stopped without any attendant staff. He knew that the Princes Risborough scheme had worked well for the first 5 years, but he had not heard how it had operated since then. In that case there were originally no service reservoirs, and that involved having pumps of sufficient capacity to meet the maximum demand; but the excess pumping capacity of pumps became useful as demands increased, and at a later stage service reservoirs could be added. As the Author had stated, however, every case should be considered according to the particular circumstances of the district.

Another matter foreshadowed by the Government White Paper, and which he thought would have a considerable influence on rural water-

supplies, was that at present there were in England and Wales more than 1,100 separate water undertakings, many of which were so small that they were unsatisfactory in regard to quantity and probably in a good many cases they were also not satisfactory in regards to quality. The Government had stated that it was their intention to see that considerable integration was carried out, which would mean the elimination of many of those small undertakings as separate entities. In such cases that would result in mains being carried out from the larger undertakings to couple up with the smaller ones whose sources were abandoned, and thus afford an opportunity to provide rural supplies in the district through which the feeder mains passed. He believed that that would be of considerable assistance.

With regard to the agricultural needs, according to the figures he had, a cow required an average of 17 gallons per day to drink, a little more than that quantity in summer and a little less in winter, whilst for other purposes about 16 gallons per day was required, making a total of 33 gallons per day, or 11,000 gallons per year. He had heard it stated that the more water one could pump into a cow the greater would be the yield of milk. If there was any truth in that statement he could not imagine the thrifty farmer stinting his cow of any liquid refreshment that it might require.

Another consideration with regard to rural water-supplies was whether the peak demands of the farms were likely to coincide with those of the domestic consumer. The latter drew more water at mid-day than at any other time during the 24 hours, and it appeared likely that the farmer would require his main supplies at other hours; but if the two peaks did coincide that was another factor affecting the size of mains.

Whilst rural water-supplies would not provide an opportunity for any spectacular engineering, they would do much help to maintain the rural population and improve the health and prosperity of the countryside.

Mr. H. F. Marriott observed that no mention was made in the Paper of the source of water-supply. In his view the source was intricately interwoven with all the methods of delivering the supply which had been mentioned by the Author.

About 54 years ago South Northamptonshire had experienced its last serious drought, and in order to overcome the consequences Mr. Marriott had laid a mile of pipe-line from the best spring on his property. That spring had only a small $\frac{3}{4}$ -inch pipe-line, and during the recent drought it had supplied 100 acres of grazing land and a considerable proportion of the village, as well as people from outside who could not obtain water anywhere else. The drought of the past 2 years, after a 50-year interval, had lowered the water table of all the surrounding country so much that nearly all the wells had dried up. It was useless to sink new wells, because the result would have been merely to drain away the water that was left in the existing wells. The water in South Northamptonshire was all taken off the top of the lower lias. It came in from Warwickshire and the

country to the north-west on the top of the lower lias, and it had been quite sufficient for all the rural districts until the new move of industries throughout the country and the building of new council houses and increased farm requirements. When he was young, people were satisfied with one bath a week, about 3 inches deep, but to-day there was a bath in every small house and people wanted to have it full. To-day industries were asking for large quantities of water and did not mind how much ran away, and the public lavatories had water running away continuously. Thus the demands for water had increased enormously. The water on the top of the lower lias could not supply the needs of the country now, and it certainly would not supply the increasing needs of all the new factories that were being erected. As a member of the Daventry Rural District Council, he had become very interested in the water problem. For a long time Northampton had been living on sewerage water derived from the open fields, which came through the pipes for only so many hours per day. It was contaminated by cattle refuse, and underwent a certain amount of chlorination. Daventry had an excellent little waterworks, which yielded 40,000 gallons of beautiful spring water per day. That was now being supplemented with about 140,000 gallons of sewerage water, to which chlorine was added, and the language of the local people was just as strong as the smell of the water! Cattle would not drink that water if they could get the water from the springs; they knew what was good!

Some people might view that matter lightheartedly, but it was a very serious danger throughout the Midlands, at any rate, because if the position remained as it was at present 6 feet of snow would be required that winter to fill the springs, and he did not think that would occur. He feared that epidemics might occur through the country. Chlorinated water could not be trusted, because it depended upon whether the local, and probably not too well paid, man who was doing the chlorination supplied the correct dosage. If he added too little, the water was worse for people to drink than the water from their contaminated wells.

The River Nen had its source in the district, and the water from it was formerly used (and was still used lower down, where it was piped out for Northampton) by the people and cattle in his district; but they could not use it to-day, because sewage-disposal works had been constructed, the effluent from which ran into the Nen.

He wished to emphasize that something far more deep-seated must be done than simply making use of the hitherto known water-supplies. People talked about having long pipe-lines and of joining up his district with Birmingham, Birmingham with Wales, and so on, but there was no necessity for anything of that kind. Not very far below the surface there were about 500 feet of blue lias and 500 feet or 600 feet of Permian. The Permian beds underlying his district were the most heavily watered in England, and there were only about 1,000–1,500 feet—at the most 2,000 feet—below the surface. Therefore it was only necessary to sink bore-

holes and all the water that was required could be obtained, without need for the provision of expensive and heavy pipe-lines.

The best evidence he could give in that connexion was the following. A good many years ago he had been interested in the founding of the Cementation Company. At that time the Coventry colliery was getting 3,000 gallons of water per minute and could not cope with or reduce it. Accordingly the Cementation Company was consulted, and that Company put the usual umbrella of cement down and sealed off the water, which was still there. Three thousand gallons of water per minute amounted to 4 million gallons a day, which would supply 200,000 people. When he talked to some of his colliery friends in the Midlands about that supply of water, they said: "If you sink wells you do not know that you will strike it." Some help might be obtained from geophysical methods, but he did not trust those methods for this purpose. Speaking as a geologist, he would not trust a geologist or any technical man to tell him where to put a well. The only method he would adopt was an empirical one. In the district where water was required, a regular chequerboard pattern should be laid out, points being taken $\frac{1}{2}$ mile or 1 mile apart, and wells should be put down—if necessary, to 2,000 feet—at every corner of the chequerboard. If only one-fourth, one-sixth, or even one-tenth, of them yielded water in the quantity that had entered the Coventry colliery, all the water that was required for the district would be obtained, and at far lower cost than by any other method. Some American drills could drill 950 feet in one day, and if they were used it would not take long to sink the wells and case them.

It was necessary to consider very seriously what the Government were going to do. If there was to be bureaucratic control and another "Grid" system, the people near at hand would take all the water and those at a distance would not get any. He took exception to the Author's statement that rural councillors were largely to blame for the present state of affairs. In his area water was flowing away in the springs that the Rural District Council wanted to pipe to the people, who had to go a mile or two with buckets to get water. The Council wanted to spend £100 on putting in pipes and a little pump, but the matter had to go through so many Government Departments that the Council got tired to death of it. At one place 16,000 gallons per day was running away, but the people in that place could not get any water. They had been trying for 2 years to get Government sanction to spend a little money in order to obtain a supply of water, but they had not been successful.

He had three sets of rain-water tanks, but he regarded them very dubiously when a drought occurred; no more water came into them in time of drought, whilst the water inside went down and down; what was one to do when it reached the bottom? What was needed in Great Britain was healthy spring water—not chlorinated water. People who had to use chlorinated water would have nothing more to do with it when

they could get pure water, and the underground supplies of the country could yield all the pure water that was wanted.

Mr. Julius Kennard observed that the Author and he had crossed swords many times, but on the present occasion he was in almost complete agreement with the Author's views as set out in the Paper. He wished especially to endorse the opening two sentences. The wide scope of the non-technical matters with which the Author had dealt was an indication of the problems with which the water engineer was confronted to-day. Those engineers who were engaged in the preparation of schemes for rural water-supplies were beginning to realize that a new technique was necessary—and by no means the least important factor in that technique was the art of salesmanship. His own experience had been that, in addition to the financial and administrative difficulties to which the Author had referred, the parochial jealousy of obstinate councillors and chairmen of water committies, and the unwarranted fear of officials that the purchase of a supply of water in bulk from a neighbouring authority might lead eventually to some further amalgamation, which they did not want to take place, had often led to the postponement of schemes, whilst, in cases where schemes had been developed, they had not been so efficiently planned as they might have been, and the full benefits of the schemes had not been received by all the people concerned.

He knew of one case a few years ago in which those advising a Rural District Council considered that the formation of a water board would be the best solution of the problem and would be advantageous to three particular authorities, two rural and one urban. One of the rural authorities was reasonably well supplied with water, and was fortunate also in having additional sources of supply in its district; yet the suggestion to form a water board met with a very cold reception. Firstly, the authority possessing the supplies felt that by surrendering its assets to a board it would suffer in prestige, because, on account of its low ratable value, its representation on the board would be very much less than that of its neighbours. Secondly, the engineer responsible for the maintenance of the undertaking, knowing his professional limitations, realized that he would not be regarded as suitably qualified to be appointed Engineer to the board. Accordingly, with the object of maintaining control, the authority and its engineer preferred to supply surplus water, as and when available, to the neighbouring districts.

In another case, about 14 years ago, Mr. Kennard's firm had prepared a report on a comprehensive scheme for a large rural district, in which area there were two fairly large centres of population, each of which was adjacent to two other water authorities. At the same time as this rural scheme was being considered, both of those neighbouring authorities quite rightly thought that they could supply those two particular centres of population more efficiently and more cheaply, and they sought the necessary powers to proceed on those lines. Notwithstanding all the appeals

that were made by the rural district, which said that the withdrawal of the two populous areas in question would jeopardize the scheme, Parliament thought otherwise and the rural district scheme had never been proceeded with. He considered that that was a case in which the national interests had not been properly served, and that if a similar problem and set of circumstances were to be considered to-day a very different and more satisfactory course would be adopted.

He strongly endorsed the Author's remarks with regard to ring mains. He did not think that the substantial saving in friction which could be obtained by a ring main was fully appreciated. For example, a discharge of 100 gallons per minute through a single 4-inch main would consume about 40 feet of head in $\frac{1}{2}$ mile of pipe, whereas by the division of the flow along two branches of a ring main the head loss was reduced to 10 feet, which was a very substantial saving to be considered in the case of rural schemes. Furthermore, dead ends and the consequent need for flushing from time to time were eliminated by the use of ring mains, and there was also a larger reserve for fire purposes.

The Author had stated that the expenditure on mains in a rural scheme was generally not less than 75 per cent. of the total cost. Mr. Kennard did not dispute that statement, except to say that it depended on whether treatment works were necessary and whether the scheme made use of any existing works. His own experience had been that the cost of the mains was not so high as 75 per cent. of the total cost; but, whatever the cost of the mains, it was essential that the pipe-lines should be not only properly designed but also efficiently laid. Some local authorities and their surveyors seemed to think that main-laying was so elementary that it did not require expert knowledge or justify competent supervision. In fact, it was even thought that the work entailed nothing more than opening a trench 3 feet or 3 feet 6 inches deep, dropping the pipes into the trench, joining the pipes, and refilling the trench with the excavated material. He had had the experience of supervising contractors who regarded it as sheer Westminster snobbery even to take sections and to insist that the pipes should be laid to proper gradients.

It went without saying, he thought, that the provision of all the necessary air-valves, sluice-valves, wash-out branches, and hydrants should be carefully considered; yet on many occasions, when called upon to investigate the delivery capacity of an existing main, he had found that insufficient or wrongly placed air-valves had resulted in greatly diminished deliveries. The efficient design of a distribution system and the need for the greatest permissible economies when planning small-diameter mains presupposed that the utmost care would be taken in laying the pipes, and he considered that engineers responsible for the design of rural water-supply schemes should deprecate any attempt on the part of authorities to entrust the constructional work to people who lacked the necessary experience.

Had the Author any knowledge of the attitude which Government

Departments were likely to take up in connexion with the many supplies that had been developed in the past 4 or 5 years for camps, aerodromes, and so forth? A good deal of water would doubtless be available when the present war-time demands disappeared, and he hoped that appropriate action would be taken to ensure that those supplies were properly utilized. He was already concerned with one case where a surplus supply of about 500,000 gallons per day was likely to be available, and already a sort of scramble for that supply was developing.

Further had the Author any confirmed experience in regard to the peak rate of flow in mains in comparison with the average rate of flow? Sir Jonathan Davidson had suggested that it was important to know whether the peak demand for farm supplies was likely to coincide with that of domestic consumers, but evidence on that point was very difficult to obtain. Mr. Kennard's own practice had been to design the mains to carry twice the average flow; but if the Author had any evidence to support or contradict that he would like to hear it.

In his view 3-inch mains ought to be discouraged and none smaller than 4-inch should be laid. He knew there was great need for economy, but, when all was said and done, the difference between the cost of 3-inch and 4-inch mains (taking pre-war values) was only about 10d. or 1s. 0d. per linear yard, which was something like 10–15 per cent. of the cost of the main; but that applied only to the particular length of 3-inch or 4-inch main. When the percentage was distributed over the total cost of the scheme it became negligible, particularly as the 4-inch main had about double the discharge capacity of the 3-inch main. In his opening remarks the Author had pointed out how rapidly the estimated ultimate requirements of a rural district scheme were reached, and Mr. Kennard felt that if a margin of reserve was available owing to 4-inch mains having been already laid, that would assist in meeting the unexpected demand that so often occurred.

Mr. G. M. C. Taylor agreed with the Author that the expenditure on mains in a regional scheme was quite likely to amount to 75 per cent. of the total cost of the scheme, especially where no treatment works were required for the water; in fact, it might be higher than 75 per cent. A recent regional scheme with which he had dealt, and which was divided into three sections, involved the construction of 92 miles of main, and he found that, of those 92 miles, 56 miles represented connecting mains between villages where the population was very small, whilst, to his surprise, the remainder were actual distribution mains in the villages, which would, in his opinion, have been common to a regional scheme and to what the Author had called a purely local scheme. Therefore when talking about the high cost of mains one should not think only of what might be called dead mains, which served only a very small population, because the cost of those mains was probably less than 50 per cent. of the cost of the scheme.

With regard to the Author's statement that "the greatest permissible

economy in mains must be exercised," he considered that for actual distribution in small villages 3-inch mains were sufficiently large, but he would say "Do not spoil the ship for a ha'porth of tar" by laying a lot of 3-inch connecting mains, because, as Mr. Kennard had said, the difference in cost between a 3-inch main and a 4-inch main was quite small. Taking 1938 prices, he estimated that a 4-inch main cost about $17\frac{1}{2}$ per cent. more than a 3-inch main; but, on the other hand, its delivering capacity at the same hydraulic gradient was 116 per cent. more. Of course, that high percentage increase in carrying capacity fell and the increase in cost rose with larger sizes. For instance, he estimated that the additional cost of a 5-inch main over a 4-inch main was about 20 per cent. and the carrying capacity of a 5-inch main was 82 per cent. higher than that of a 4-inch main, whilst a 6-inch main cost 22 per cent. more than a 5-inch main and had a 50-per cent. higher carrying capacity.

He appreciated the Author's confession that "when the laying of miles of mains into strictly rural districts commenced he regarded it as a species of madness and even now his logical mind rebels against it at times", because he himself had had the same feeling; but, having gone into the question, he had no doubt that the regional scheme was the best permanent solution of the problem with which water engineers had to deal.

There were other matters determining the optimum size of an undertaking besides efficient control and management, an important one being the configuration of the land—the difference in height between the service reservoirs and the area of the country to be supplied with water. Another factor of importance in the same connexion was the distance between the source of supply and the suitable position for the service reservoir. In some cases there was only one possible position for the source of supply and one possible position for the service reservoir. It was fortunate if those two positions happened to be close together. If they lay far apart, it might be necessary to modify the design of the scheme and to curtail the area of supply.

The County War Agricultural Committees had been extremely helpful in supplying details of the cow population of the rural district, and also of every parish in the whole of the rural districts. Those data showed that the number of cows was almost exactly double that of human beings, but it was not stated whether they were horned beasts or cows in milk. After talking to people in rural districts he had come to the conclusion that, so far as engineers were concerned at the moment, they had to pay a great deal of attention to the cow in milk, but the rest of the horned beasts would not consume nearly so much water, and they could drink from brooks, streams, ponds, or ditches. He did not think that the health of the rural population, either human or animal, would suffer in any way if those animals which were not milked continued to drink from the sources that had been utilized for the last thousand years.

Mr. J. H. T. Stilgoe observed that water-consumption for agricultural

purposes was based chiefly on the cow in milk, but it could also be calculated by the acreage of farm land. In obtaining figures concerning the water-consumption of the cow and the stock in any area, he had been greatly helped by the War Agricultural Executive Committee. The Ministry of Agriculture took as a basis a "cow-equivalent unit", which was the water-demand of one cow in milk, and other stock were related to the cow-equivalent unit. The normal demand for all purposes of a cow in milk was taken to be 30 gallons per day, and from that the following Table was obtained :—

Stock.	Normal demand in gallons per head per day.	Head of stock to one cow-equivalent unit.
Cow, in milk.	30	1
Other horned stock (bullocks, dry cows, etc.)	10	3
Horses, at work	10	3
Horses, at pasture	6	5
Pigs	3	10
Sheep	1½	20
Goats	1	30
Poultry	1/20	600

Where the head of stock given for a particular farm or district made no distinction among horned stock, but expressed the whole as cows, it might be assumed that on a dairy farm half were cows in milk and that on a mixed farm one-third were cows in milk.

If the cow population was not given, but only the acreage, fairly good working figures were the following: On the best land, one cow on 2½ acres; on ordinary land, one cow on 3 acres; and, on poor land, one cow on 5 acres.

In his area the Ministry of Agriculture regarded a farm as being understocked if it had fewer than twenty cows, or their equivalent, per 100 acres farmed. It was the policy of the Ministry to bring up the stock population to the figure of twenty cows to 100 acres, and water undertakings were expected to estimate for that in their schemes.

It was interesting to note how the demand per cow in milk was made up. For drinking, a cow in milk required a maximum of between 40 gallons and 50 gallons per day in hot weather, of which it might take 10 gallons in a single draught. The minimum it required for drinking was 10 gallons per day. The demand varied with the weather, the feed, and the quantity of milk being yielded. It would increase with dry feed, such as hay, and would decrease with moist feed. In a neighbouring district to his own, where the water demand was almost entirely a farm demand, a peak occurred in the winter as well as in the summer, owing to dry feed for the cows.

The average or normal demand for cows for drinking was taken by the Ministry of Agriculture as 15 gallons per head per day, whilst various authorities had given it as 10, 13, 16, 17 to 20, and 20 gallons. It varied

for many natural reasons. Of the water drunk, 8 gallons was said to be required for maintaining the cow (its body), and 2-3 gallons was said to be required by the cow for each gallon of milk that it produced. Therefore the demand on the mains depended on the yield of the individual cows in milk. The average quantity of milk produced by a cow was 2-2½ gallons per day, whilst the very best milker would yield 6-7 gallons per day.

Milk was given by the cow at a temperature ranging from 90° F. to 95° F., and should be cooled to 60° F. A Statutory Rule and Order, dated 1926, required milk to be cooled down to not more than 5° F. above the cooling-water temperature. The ideal cooling-water temperature was 40° F. Water issued from chalk at a temperature of 51°-52° F., and that was the lowest temperature which could be obtained in practice. Some farms installed freezing apparatus for cooling milk, and there the demand for water for cooling was considerably lower.

Water was also required for washing flanks and udders and milkers' hands, for cleaning utensils and the dairy, and for washing the cowshed floors. Various quantities were estimated as being required for these purposes, but the Ministry of Agriculture assumed that 15 gallons per day was required for cooling and cleansing. The bulk of the cooling water could be re-used.

The following Table gave the quantities in detail for one cow in milk :—

	In detail for 2½ gallons of milk per day.	Ministry of Agriculture.
	Gallons per day.	Gallons per day.
<i>Drinking :</i>		
Maintenance	8	
Production (2-3 gallons of water per gallon of milk)	6	
Total	14	15
<i>Cooling</i> (6 gallons of water per gallon of milk)	15	15
<i>Cleansing</i>		
Flanks, udders, and milkers' hands	2	
Dairy and utensils	2	
Cowshed floor, twice daily	10	
	43	
Less proportion of cooling water re-used, say	13	
All Purposes	30	30

The most important feature in agricultural supplies was the peak load for 1 hour, which occurred usually during or just after the morning milking, namely, between 6.30 a.m. and 8 a.m. In the afternoon there was another peak between 3 and 4 o'clock. In some villages the practice differed, and

the afternoon peak load might be as late as 6 o'clock. The following was an example of the peaks for a herd of twenty cows in milk. For such a herd there would be about twenty followers, and allowance should be made for those drinking at the same time as the cows were being milked.

		Gallons.	Gallons.
<i>Daily Consumption :</i>			
Cows in milk,	20 at 30 gallons per head per day		600
Followers,	20 at 10 ,, ,, ,,		200
			800
consisting of			
<i>Drinking :</i>			
20 at 15 gallons per head per day		300	
20 at 10 ,, ,, ,,		200	
		500	
and			
<i>Cooling and Cleansing :</i>			
20 at 15 gallons per head per day		300	
		300	
			800

The latter being required as follows :

<i>After morning milking :</i>	
say 25 gallons (maximum would be 30 gallons), milk to be cooled in 1 hour with 6 gallons of water per gallon of milk.	150
cleansing water shortly after, say	25
<i>After afternoon milking :</i>	
say 17-18 gallons (maximum would be 20 gallons), milk to be cooled in $\frac{3}{4}$ hour with 6 gallons of water per gallon of milk	105
cleansing water shortly after, say	20
	<hr/> 300

Maximum demand in one hour, therefore, at cooling time is made up of

Cooling	20 Cows (with bowls), say at 1½ gallons	30
Drinking.	20 Followers „ 1 gallon	20
		— 200

Therefore, in the absence of local storage and means of restricting flow into it, the main capacity provided should be sufficient to enable one-quarter of the daily demand of the herd to be taken in one hour.

* * **Mr. T. E. Hawksley** observed that the Author had not disclosed by what process he had arrived at 300 as the nominator in his modified formula on p. 17. Was that a misprint or the result of assuming that the lower figure was used because the householder was content to provide storage to equalize over only one year, and that not the worst of the three dry years?

The fallacy in the argument was that the householder had to start

. This and the following contribution were submitted in writing.

restricting himself early in the year in order to tide over a future drought. Were all such householders to be deemed to be students of Old Moore's Almanack, or followers of some prophet of less renown but greater accuracy? If so, who was the prophet?

Mr. R. C. S. Walters observed that he was glad that the Author had "come to be a believer in adequate rural schemes", and that his conscience was clear to lay 1 mile of such main per two cottages, which, incidentally, appeared to be the "target" for post-war rural water-supplies.

Mr. Walters was strongly in agreement with the many statements which had been expressed so well in the Paper, and was pleased that the Author had not dwelt on the incidental engineering matters such as boosting or gravitation, consumption per head of man and beast, their birth-rates, scraping, treatment, and other vexations which only tended to side-track the "main" question, the financing of the distribution main (£100,000 per 50 miles).

He had found a remarkable change up and down the country, and an urgent cry for water to be "laid on" in rural districts. He attributed that to the prosperity of agriculture, the appreciation of the time saved in piped water, the better milk, and the cleaner conditions.

He considered that the time was ripe to make a great drive to create a national asset of the first order so that the Ministry of Health might be well supported and not be blocked by financial considerations; in any case, it was not economy to pay a man £3 per week to look after a chlorinating-plant for 20,000 gallons per day, and it was not right that a sanitary inspector or surveyor should be responsible for many "water works" scattered over an area of 500 square miles.

Rural water-supplies should be treated from the widest possible standpoint, regarding the present situation as a national scandal and the future as a national need.

The Author, in reply observed that Mr. Stilgoe's statement, that one-quarter of the day's supply of water might be taken in an hour, was doubtless true for an individual consumer's service supply; but if water undertakings were to lay their mains for anything like that peak the cost that would be incurred for the benefit of what, after all, was a trade supply would be, to his mind, ridiculous. The Devon County Council had a Bill before Parliament that Session for promoting a Water-Board, and that problem had been safeguarded in the Bill by a clause to the effect that where the demand of an agricultural or an industrial consumer was such as was likely to cause an abnormal demand on the mains, obligation should be imposed upon that consumer to provide storage capacity. The farmer might complain because he would say that he wanted really cold water; but he could not always be sure of having that, even if it came direct from the main, and in any event the water derived from storage would be cold enough for the purpose for which it was required. It was quite unjustifiable for any consumer to expect to be able to take water at the rate in

question for such a short time, especially as his neighbours might also be taking it in the same way at the same time.

A rural scheme in itself should, as far as possible, contain more balancing tanks and local storage than would ordinarily be the case, because it was obviously more economical to provide combined storage for a number of local consumers than to make each consumer provide his own; but otherwise provision of storage by the consumer himself was the best solution of the problem of the peak supply.

He agreed with the remarks of Messrs. Stilgoe and Taylor upon the demand of the cow, as very similar figures had been supplied to him, and he also agreed that the War Agricultural Committees were very helpful in the matter. If the number of cows was not known, the figures could be obtained by working backwards from the milk-production. A milkman was not allowed to create milk from water, but cows required various quantities of water for the production of one gallon of milk. Cleansing and cooling were two of the largest factors, but many up-to-date farmers installed inter-coolers, which reduced appreciably the quantity of water required for cooling.

Mr. Taylor had stated that the limits of an undertaking were very largely governed by levels; but surely an engineer should not say: "I cannot get there." He had to get there, if the district had to be supplied with water. If the water would not flow in the ordinary way, it had to be pumped. The Author agreed, however, that topographical features often imposed a limit on the distance to which water should be taken.

Mr. Kennard had asked whether he knew what was in the mind of the Government. He could not answer that question except by saying he had been informed semi-officially that all the supplies and works constructed for Service requirements to which Mr. Kennard had referred would not be dismantled without local or water authorities having an opportunity to buy them—presumably at bargain prices.

Sufficient experience had not yet been obtained to show how the peak demand would average out on rural supplies, in comparison with the normal experience in the case of urban supplies. It was certain that if adequate storage were not provided in the case of some of the supplies the peak demands might be very high.

Both Mr. Kennard and Mr. Taylor had commented on the statement that the cost of mains would not be less than 75 per cent. of the total cost of a rural scheme. It was obvious that a regional scheme might be all mains; in the case of a bulk supply there would be nothing else. Two rather large schemes which he had prepared involved treatment plant and storage reservoirs, and they were complete in themselves. The principal mains accounted for 74 per cent. of the total cost of one scheme, and 84 per cent. of the other.

His former chief used to say that anybody who buried a pipe of less than 4 inches ought to be buried with it, and there was a great deal of truth in

that ; but laying in a village a main far larger than was required could not be justified, unless there was a possibility of extension. If the main had definite limitations and could not be extended, he agreed with Mr. Taylor that a 3-inch main should be used, because it really had a very high capacity.

He could not agree with Mr. Marriott's suggestion that if a series of squares was marked out all over the country and boreholes were put down the water problem would be solved. Many boreholes had been put down, perhaps not in squares, but they had not produced water.

The statement in the Paper that works to the value of about £6,000,000 had been constructed in consequence of the Government grant of £1,000,000 had been taken from the White Paper. The Author confessed that it had surprised him, because some authorities had obtained grants which were only a very small percentage of the cost of the work they carried out and if only £6,000,000 worth of work was done others must have obtained much larger grants.

He had not personally seen the little scheme at Princes Risborough to which Sir Jonathan Davidson had referred, and which really was a regional scheme ; but he knew the engineer who was now in control of it, and he could say definitely that it had required more supervision than Sir Jonathan might think was the case.

In reply to Mr. T. E. Hawksley, the formula on p. 17 for rain-water storage was not a misprint. It had been obtained from assumptions that suggested the storage might be only 60 per cent. of that obtained from the well-known Hawksley formula and that there were advantages in retaining the same form. All water-supply dependent upon storage would have the same disadvantage referred to by Mr. Hawksley, though it would be agreed that the greater the storage the less was the anxiety. The Author agreed with Mr. Walters as to the importance of all water-supplies being grouped so as to allow of technically efficient control being economically practicable.